



कोल्हापूर महानगरपालिका

पोस्ट बॉक्स नं. ३३, पिन कोड नं. - ४१६ ००२.

फोन नं.-पी.बी.एक्स. बोर्ड २५४०२९१ ते २५४०२९८



जाचक क्र.- अग्निशमन विभाग / वशि-१/ ८९९ /२०२४-२५

दि.: ०६/०३/२०२५

प्रति,

डॉ. दिपक आनंद पाटील,

नेबापूर, ता.पन्हाळा, जि.कोल्हापूर



विषय :- डॉ. दिपक आनंद पाटील, बोरपाडळे फाटा मु.पो. नेबापूर, ता.पन्हाळा, जि.कोल्हापूर यांचे (संजीवनी आयुर्वेदिक हॉस्पिटल) ६० बेड हॉस्पिटल इमारतीसाठी ना-हरकत दाखला बाबत...

संदर्भ :- १. संचालक, महाराष्ट्र अग्निशमन सेवा संचालनालय यांचा आदेश दि.२७/०१/२०२१

२. ग्लोबल प्रोटेक्शन सिस्टीम यांचा दि. ०१/०१/२०२५ चा बी फॉर्म लायसन

नं. MFS- LA/RF-224

उपरोक्त विषयांकीत कामी संदर्भिय पत्रान्वये डॉ. दिपक आनंद पाटील, बोरपाडळे फाटा मु.पो. नेबापूर, ता.पन्हाळा, जि.कोल्हापूर यांचे (संजीवनी आयुर्वेदिक हॉस्पिटल) ६० बेड हॉस्पिटल मध्ये बसविणेत आलेल्या अग्निप्रतिबंधक सुविधा दुरुस्त आणि कार्यक्षम स्थितीत असलेबाबत अग्निशमन विभागाचा ना-हरकत दाखला मागणी केलेला आहे.

उपरोक्त ठिकाणी संचालक, महाराष्ट्र राज्य अग्निशमन सेवा संचालनालय यांनी दिलेल्या आदेशाने महाराष्ट्र आग प्रतिबंधक व जीव संरक्षक उपाययोजना २००६ भाग ४ नुसार आपल्या हॉस्पिटल मध्ये बसवण्यात आलेली अग्निशमन सुविधांची कोल्हापूर महानगरपालिका अग्निशमन विभागाने तपासणी केली असून ग्लोबल प्रोटेक्शन सिस्टीम यांचा दि. ०१/०१/२०२५ चा बी फॉर्म लायसन नं. MFS- LA/RF-224 प्रमाणे १.) ए.बी.सी. - ०४ नग, सी.ओ.टु-१ २) पंप- १०० एल.पी.एम, ३) होजरील - ०४ नग, हायड्रंट व्हॉल्व-०४, हुटर-०४, एम.सी.पी.०४, ४) फायर इनलेट टु वे -१, बसवलेली आहे. सदर यंत्रणा आज मितीला कार्यक्षम व सुस्थितीत असले बाबत नमुद केले असल्याने त्यांना इकडील विभागा कडून ना-हरकत दाखला देण्यात येत आहे. सदरचा दाखला हा केवळ मुंबई शुश्रूषा गृह नोंदणी साठी वापरण्याचा आहे.

महाराष्ट्र आग प्रतिबंधक व जीव संरक्षक उपाययोजना २००६ भाग ४ मधिल कलम ३ (पोट कलम ३) नुसार सदरची यंत्रणा सुस्थितीत व कार्यसुन असले बाबत मान्यताप्राप्त लायसन एजन्सी यांचा बी फॉर्म वर्षातून दोन वेळा म्हणजे जानेवारी व जुलै महिन्यात सादर करण्याचा आहे अन्यथा सदरचा ना-हरकत दाखला रद्द समजण्यात येईल. सदरचा दाखला एक वर्षाचे मुदतीकरिता देण्यात येत आहे. ६० बेड हॉस्पिटल परवानाकामी आग सुरक्षा निधी GD2002133202410502 रक्कम ३०,२५०/- रुपये दिनांक ०६/०३/२०२५ रोजी भरण्यात आले आहे.

मुख्य अग्निशमन अधिकारी
कोल्हापूर महानगरपालिका

DATE: 01.01.2026.

FORM B

{See section 3(3) and rules 4 (2)}

Six monthly Certification to be given in every January and July by the occupier for compliance of the fire prevention and life safety measures.

CERTIFICATE

Certified that I/we have carried out inspections of the fire prevention and life safety measures installed in following building or premises namely.

M/s. Dr. Deepak Patil Ayurvedic Medical Collage

Gat No. 216-A, Borpadale Phata,
Borpadale, (Nehapur),
Tal- Panahala, Dist-Kolhapur.

I/ We further certify that this installation in the above-mentioned buildings is maintained in good repair and efficient conditions during the period **1st July 2025 to 31st December 2025**, as required under the provision of the Maharashtra Fire Prevention & Life Safety Measure Act, 2006(**Mah-III of 2007**). The detail of the inspection & maintenance of installation carried out by me/us are mentioned in the report appended her with

Details of inspection and maintenance /servicing are as per attached list

ZUBAIR

IBRAHIM

SUBHEDAR

Digitally signed

by ZUBAIR

IBRAHIM

SUBHEDAR

Date: 2026.01.01

11:38:43 +05'30'

Signature & address of
the licensed agency.

Name, Signature &

Stamp of the organization

License No: MFS/LA/RF-224.

Next Due Date: 30.06.2026.



DATE: - 01.01.2026.

TEST CERTIFICATE

{See section 3(3) and rules 4 (2)}

Certified that I /we have carried out inspection of fire prevention & Life Safety Measures installed in the following building or premises namely.
(Building Numbers, society Name & address-

M/s. Dr. Deepak Patil Ayurvedic Medical Collage

Gat No. 216-A, Borpadale Phata,
Borpadale, (Nehapur),
Tal- Panahala, Dist-Kolhapur.

We further certify that these installation in the above-mentioned buildings are maintained in good repair and efficient conditions during the period ONE YEAR, as required under the provision of the Maharashtra Fire Prevention & Life Safety Measure Act, 2006(Mah-III of 2007). The detail of the inspection & maintenance of installation carried out by me/us are mentioned as below herewith.

Details of inspection & Maintenance/Serviceing

Following List of Material are installed & tested successfully.

Sr. No.	Particulars	Qty.	Remark
1	Fire Pump 15 HP	01 Nos.	Ok
2	Hose Reel Drum Set	08 Nos.	Ok
3	Hydrant Valve Point	08 Nos.	Ok
4	Fire Brigade Connection Two Way	01 Nos.	Ok
5	ABC Type 06 Kg Fire Extinguisher	08 Nos.	Ok

License No: MFS/LA/RF-224.

Next Due Date: 30.06.2026.



GLOBAL PROTECTION SYSTEMS

Subhakar
PROPRIETOR

DATE: 01.01.2026.

FORM B

{See section 3(3) and rules 4 (2)}

Six monthly Certification to be given in every January and July by the occupier for compliance of the fire prevention and life safety measures.

CERTIFICATE

Certified that I/we have carried out inspections of the fire prevention and life safety measures installed in following building or premises namely.

Sanjeevani Ayurvedic Hospital

Borpadale Phata, Kolhapur – Ratnagiri Highway,
Tal- Panhala, Dist. Kolhapur.

I/ We further certify that this installation in the above-mentioned buildings is maintained in good repair and efficient conditions during the period **1st July 2025 to 31st December 2025**, as required under the provision of the Maharashtra Fire Prevention & Life Safety Measure Act, 2006(**Mah-III of 2007**). The detail of the inspection & maintenance of installation carried out by me/us are mentioned in the report appended her with

Details of inspection and maintenance /servicing are as per attached list

ZUBAIR

IBRAHIM

SUBHEDAR

Digitally signed by
ZUBAIR IBRAHIM
SUBHEDAR

Date: 2026.01.01
15:56:11 +05'30'

Signature & address of
the licensed agency.

Name, Signature &

Stamp of the organization

License No: MFS/LA/RF-224.

Next Due Date: 30.06.2026.



DATE: - 01.01.2026.

Test Certificate

{See section 3(3) and rules 4 (2)}

Certified that I /we have carried out inspection of fire prevention & Life Safety Measures installed in the following building or premises namely.

(Building Numbers, society Name & address-

Sanjeevani Ayurvedic Hospital

Borpadale Phata, Kolhapur – Ratnagiri Highway,

Tal- Panhala, Dist. Kolhapur.

We further certify that these installation in the above-mentioned buildings are maintained in good repair and efficient conditions during the period ONE YEAR, as required under the provision of the Maharashtra Fire Prevention & Life Safety Measure Act, 2006(Mah-III of 2007). The detail of the inspection & maintenance of installation carried out by me/us are mentioned as below herewith.

Details of inspection & Maintenance/Serviceing

Following List of Material are installed & tested successfully.

Sr.no.	Description	Qty.	Remark
1	Fire Pump 900 LPM	01 Nos.	Ok
2	Hydrant Valve Point	04 Nos.	Ok
3	Hose Reel Drum Set	04 Nos.	Ok
4	Fire Brigade Connection 2 Way	01 Nos.	Ok
5	ABC Type 06 Kg Fire Extinguisher	04 Nos.	Ok
6	Co2 Type 4.5 Kg Fire Extinguisher	01 Nos.	Ok
7	MCP	04 Nos.	Ok
8	Hooter	04 Nos.	Ok
9	Smoke Detector	10 Nos.	Ok
10	Alarm Panel 2 Zone	01 Nos.	Ok

License No: MFS/LA/RF-224.

Next Due Date: 30.06.2026.



GLOBAL PROTECTION SYSTEMS

S. Subhakar
PROPRIETOR